

A Division of DW Pearce Enterprises Ltd . (1979)

Contact us by telephone, fax

Tel: (604) 576 - 2212 Fax: (604) 576 - 7773 www.Eaglecoatings.net

Ratings/Approvals:

U.S. Testing Corporation ASTM E-84 5/4/95 Flame spread = 5 Smoke developed = 20

California State Fire Marshall #2280-1340-101

California State Fire Marshall Registration No. C-20404

City of Los Angeles, RR #25232